

Long Reach High School - 3rd Floor Classrooms
Unit Ventilator Outdoor Air Damper Confirmation Worksheet

3/1/21

Timestamp:	School Name:	Unit Ventilator No.:	Area Served:	Proper Operation of Outdoor Air Damper:	If no, explain:	OA Damper Operation Confirmed By:
2/3/2021 13:42:32	Long Reach HS	UV-300	300	Yes		Tom Grimes
2/3/2021 13:43:16	Long Reach HS	UV-302	302	Yes		Tom Grimes
2/3/2021 13:43:42	Long Reach HS	UV-304	304	Yes		Tom Grimes
2/3/2021 13:44:14	Long Reach HS	UV-306	306	Yes		Tom Grimes
2/3/2021 9:58:55	Long Reach HS	UV-307	307	Yes		Andrew Burns
2/3/2021 13:45:37	Long Reach HS	UV-310	310	Yes		Tom Grimes
2/3/2021 9:59:41	Long Reach HS	UV-311	311	Yes		Andrew Burns
2/3/2021 13:47:02	Long Reach HS	UV-312	312	Yes		Tom Grimes
2/3/2021 10:00:08	Long Reach HS	UV-313	313	Yes		Andrew Burns
2/3/2021 10:00:54	Long Reach HS	UV-313A	313A (inside 313)	Yes		Andrew Burns
2/3/2021 13:47:32	Long Reach HS	UV-314	314	Yes		Tom Grimes
2/3/2021 13:48:14	Long Reach HS	UV-316	316	Yes		Tom Grimes
2/3/2021 13:49:14	Long Reach HS	UV-318	318	Yes		Tom Grimes
2/4/2021 13:30:16	Long Reach HS	UV-320	320	Yes		Tom Grimes
2/4/2021 13:33:28	Long Reach HS	UV-322	322	Yes		Tom Grimes
2/3/2021 10:01:33	Long Reach HS	UV-323	323	Yes		Andrew Burns
2/4/2021 13:32:46	Long Reach HS	UV-324	324	Yes		Tom Grimes
2/3/2021 10:02:10	Long Reach HS	UV-325	325	Yes		Andrew Burns
2/4/2021 13:35:47	Long Reach HS	UV-326	326	Yes		Tom Grimes
2/4/2021 13:36:36	Long Reach HS	UV-328	328	Yes		Tom Grimes
2/4/2021 13:37:33	Long Reach HS	UV-330	330	Yes		Tom Grimes
2/4/2021 13:38:39	Long Reach HS	UV-332	332	Yes		Tom Grimes
2/3/2021 10:02:58	Long Reach HS	UV-333	333	Yes		Andrew Burns
2/4/2021 13:39:30	Long Reach HS	UV-334	334	Yes		Tom Grimes
2/3/2021 13:35:25	Long Reach HS	UV-335	335	Yes		Andrew Burns
2/3/2021 13:36:04	Long Reach HS	UV-335A	335A	Yes		Andrew Burns
2/4/2021 13:40:19	Long Reach HS	UV-336	336	Yes		Tom Grimes
2/4/2021 13:41:39	Long Reach HS	UV-336	336	Yes		Tom Grimes
2/4/2021 13:42:23	Long Reach HS	UV-340	340	Yes		Tom Grimes
2/3/2021 13:36:45	Long Reach HS	UV-341	341	Yes		Andrew Burns
2/4/2021 13:43:19	Long Reach HS	UV-342	342	Yes		Tom Grimes
2/3/2021 13:37:18	Long Reach HS	UV-343	343	Yes		Andrew Burns
2/4/2021 13:44:44	Long Reach HS	UV-344	344	Yes		Tom Grimes
2/4/2021 13:45:50	Long Reach HS	UV-346	346	Yes		Tom Grimes
2/3/2021 9:52:59	Long Reach HS	UV-348	348	Yes		Andrew Burns
2/3/2021 13:41:49	Long Reach HS	UV-348A	348A	Yes		Tom Grimes

Long Reach High School - 3rd Floor Classrooms
Unit Ventilator Outdoor Air Damper Confirmation Worksheet

3/1/21

Timestamp:	School Name:	Unit Ventilator No.:	Area Served:	Proper Operation of Outdoor Air Damper:	If no, explain:	OA Damper Operation Confirmed By:
2/3/2021 9:54:04	Long Reach HS	UV-350	350	Yes		Andrew Burns
2/3/2021 9:54:50	Long Reach HS	UV-352	352	Yes		Andrew Burns
2/3/2021 9:55:38	Long Reach HS	UV-354	354	Yes		Andrew Burns
2/3/2021 9:56:20	Long Reach HS	UV-356	356	Yes		Andrew Burns
2/3/2021 9:58:08	Long Reach HS	UV-358	358	Yes		Andrew Burns

**Long Reach High School
Exhaust Fan Confirmation Worksheet**

3/1/21

Timestamp:	School Name:	Exhaust Fan No.:	Proper Operation of Exhaust Fan:	If no, explain:	Notes:	Operation Confirmed By:
10/29/2020 8:59:59	Long Reach HS	EF-01	Yes		Wall switch in room 352. Dome was lose and has been repaired.	Tom Grimes
10/29/2020 9:02:36	Long Reach HS	EF-02	Yes		Wall switch in 254. Lose dome repaired and belt replaced.	Tom Grimes
10/29/2020 9:06:10	Long Reach HS	EF-03	Yes		Direct Drive. Replaced Motor.	Tom Grimes
10/29/2020 9:07:56	Long Reach HS	EF-04	Yes		Direct Drive. Varispeed control switch was faulty and needed to be replaced.	Tom Grimes
2/22/2021 12:54:47	Long Reach HS	EF-05	Yes			Tom Grimes
10/29/2020 9:21:49	Long Reach HS	EF-06	Yes		On local switch. Oiled bearings.	Tom Grimes
10/29/2020 9:23:24	Long Reach HS	EF-08	Yes		Replaced motor & belt.	Tom Grimes
10/29/2020 9:24:53	Long Reach HS	EF-09	Yes		Replaced motor, repaired dome.	Tom Grimes
10/29/2020 9:26:22	Long Reach HS	EF-10	Yes		On switch in room 356.	Tom Grimes
10/29/2020 9:29:04	Long Reach HS	EF-18	Yes		Replaced motor. Adjusted damper.	Tom Grimes
10/29/2020 9:30:29	Long Reach HS	EF-19	Yes		Replaced belt and greased bearings.	Tom Grimes
10/29/2020 9:31:35	Long Reach HS	EF-20	Yes		Repaired dome, and replaced belt.	Tom Grimes
10/29/2020 9:33:17	Long Reach HS	EF-21	Yes		Repaired dome, and replaced belt.	Tom Grimes
10/29/2020 9:34:16	Long Reach HS	EF-22	Yes		Repaired dome & replaced belt.	Tom Grimes

**Long Reach High School
Exhaust Fan Confirmation Worksheet**

3/1/21

Timestamp:	School Name:	Exhaust Fan No.:	Proper Operation of Exhaust Fan:	If no, explain:	Notes:	Operation Confirmed By:
10/29/2020 9:35:12	Long Reach HS	EF-23	Yes		Repaired dome & replaced belt.	Tom Grimes
10/29/2020 9:37:24	Long Reach HS	EF-25	Yes		Repaired dome, replaced belt & greased bearings.	Tom Grimes
10/29/2020 9:39:44	Long Reach HS	EF-26	Yes		Replaced entire fan assembly. Oiled sleeve bearings.	Tom Grimes
10/29/2020 9:41:14	Long Reach HS	EF-27	Yes		Replaced motor, changed belt & greased bearings. Repaired lose dome	Tom Grimes
10/29/2020 9:42:24	Long Reach HS	EF-28	Yes		Repaired dome & replaced belt	Tom Grimes
10/29/2020 9:43:33	Long Reach HS	EF-29	Yes		Repaired dome & replaced belt	Tom Grimes
10/29/2020 9:44:48	Long Reach HS	EF-30	Yes		Repaired dome & replaced belt.	Tom Grimes
10/29/2020 9:45:51	Long Reach HS	EF-31	Yes		Repaired dome & replaced belt	Tom Grimes
10/29/2020 9:47:31	Long Reach HS	EF-32	Yes		Repaired dome & replaced belt	Tom Grimes
10/29/2020 8:51:19	Long Reach HS	EF-42	Yes		Repaired the loose dome, replaced the belt, returned it to service	Tom Grimes
10/29/2020 8:53:21	Long Reach HS	EF-43	Yes		Repaired loose dome, replaced the belt, returned it to service.	Tom Grimes
10/29/2020 8:58:51	Long Reach HS	EF-44	Yes		Repaired loose dome, replaced the belt, returned to service.	Tom Grimes

**Long Reach High School
Exhaust Fan Confirmation Worksheet**

3/1/21

Timestamp:	School Name:	Exhaust Fan No.:	Proper Operation of Exhaust Fan:	If no, explain:	Notes:	Operation Confirmed By:
10/29/2020 9:02:49	Long Reach HS	EF-45	Yes		Replaced the motor and sheave, replaced the belt, returned it to service, checked operation (OK).	Tom Grimes
10/29/2020 9:27:34	Long Reach HS	EF-47 Room B-126	Yes		Replaced the motor and adjusted the damper, returned it to service.	Tom Grimes
10/29/2020 9:31:10	Long Reach HS	EF-48 Room B-132	Yes		Replaced the motor and belt, repaired the dome, returned it to service.	Tom Grimes
10/29/2020 9:34:34	Long Reach HS	EF-49 Room B-128	Yes		Replaced the motor and belt, repaired the dome, returned it in service.	Tom Grimes
10/29/2020 9:39:12	Long Reach HS	EF-50 Rooms B-140, B-142	Yes		This fan was replaced.	Tom Grimes
10/29/2020 9:42:37	Long Reach HS	EF-51 Auditorium cat walk A-147	Yes		Replaced the motor, sheave and belt, repaired the dome.	Tom Grimes
10/29/2020 9:45:33	Long Reach HS	EF-52 Auditorium cat walk A-147	Yes		Replaced the motor, sheave and belt, repaired the dome returned it to service.	Tom Grimes
10/29/2020 9:47:44	Long Reach HS	EF-53 A-140 Stage area.	Yes		Replaced the belt, greased the bearings.	Tom Grimes
10/29/2020 9:50:23	Long Reach HS	EF-54	Yes		Replaced belt & greased bearings. Repaired lose dome.	Tom Grimes
10/29/2020 9:52:48	Long Reach HS	EF-56	Yes		Replaced motor & changed belt. Repaired lose dome.	Tom Grimes

**Long Reach High School
Exhaust Fan Confirmation Worksheet**

3/1/21

Timestamp:	School Name:	Exhaust Fan No.:	Proper Operation of Exhaust Fan:	If no, explain:	Notes:	Operation Confirmed By:
10/29/2020 9:55:08	Long Reach HS	EF-57	Yes		Replaced belt. Repaired lose dome.	Tom Grimes
2/22/2021 12:55:35	Long Reach HS	EF-57	Yes			Tom Grimes
10/29/2020 9:52:33	Long Reach HS	EF-58 B-134 Main gym	Yes		Replaced the belt, greased bearings.	Tom Grimes
10/29/2020 9:55:13	Long Reach HS	EF-59 B-134 main gym	Yes		Replaced the and greased bearings.	Tom Grimes
10/29/2020 9:57:43	Long Reach HS	EF-60 Main gym B-134	Yes		Replaced the belt and greased the bearings.	Tom Grimes
10/29/2020 10:00:18	Long Reach HS	EF-61 Auxiliary gym B-130	Yes		Replaced the belt and greased the bearings.	Tom Grimes
10/29/2020 10:02:14	Long Reach HS	EF-62 Auxiliary gym B-130	Yes		Replaced the belt and greased the bearings.	Tom Grimes

Long Reach HS
Air Filter and Belt Inventory



Unit No.	Unit Location	Area Served	1" Filters				2" Filters				4" Filters				12" Filters				Belts													
			Size 1	Quan.	Size 2	Prefilter?	Size 1	Quan.	Size 2	Size 3	Quan.	Prefilter?	Size 1	Quan.	Header?	Size 2	Quan.	Header?	Size 1	Quan.	Header?	Size 2	Quan.	Header?	Size 1	Quan.	Size 2	Quan.	Size 3	Quan.	Size 4	Quan.
CUH-1	Main Entrance Lobby	Main Entrance	10"x22"x1"	1																												
CUH-10	Cafeteria Exit	Cafeteria Exit	10"x22"x1"	1																												
CUH-11	Stairwell B	Stairwell B	10"x22"x1"	1																												
CUH-12	Stairwell B Exit	Stairwell B Exit	10"x22"x1"	1																												
CUH-13	Outdoor Concession Stand	Concession Stand	9"x20"x1"	1																												
CUH-14	Womens Room Outdoor Concession	Womens Room	9"x20"x1"	1																												
CUH-15	Mens Outdoor Bathroom Concession	Mens Room	9"x20"x1"	1																												
CUH-2	Stairwell A	Stairwell A	10"x22"x1"	1																												
CUH-3	Auditorium Exit	Auditorium Exit	10"x22"x1"	1																												
CUH-4	Auditorium Exit	Auditorium Exit			10"x42"x1	1																										
CUH-5	Wrestling Exit	Wrestling Exit	10"x22"x1"	1																												
CUH-6	Stairwell D	Stairwell D	10"x48"x1"	1																												
CUH-7	Stairwell C	Stairwell C	10"x22"x1"	1																												
CUH-8	Mechanical Room Exit	Mechanical Room Exit	10"x22"x1"	1																												
CUH-9	Kitchen Exit	Kitchen Exit	10"x22"x1"	1																												
FCU-200A	Ceiling	Room #200A	10"x12"x1"	2																												
FCU-200B	Ceiling	Room #200B	10"x12"x1"	2																												
FCU-209B	Ceiling	Room #209B	12"x15"x1"	2																												
FCU-220	Ceiling	Classroom #220	10"x36"x1"	1																												
FCU-222	Ceiling	Classroom #222	10"x60"x1"	1																												
FCU-223	Ceiling	Classroom #223	12"x15"x1"	2																												
FCU-224	Ceiling	Classroom #224	10"x60"x1"	1																												
FCU-226	Ceiling	Classroom #226	10"x60"x1"	1																												
FCU-227	Ceiling	Classroom #227	10"x12"x1"	2																												
FCU-228	Ceiling	Classroom #228	10"x60"x1"	1																												
FCU-230	Ceiling	Classroom #230	10"x60"x1"	1																												
FCU-232	Ceiling	Classroom #232	10"x60"x1"	1																												
FCU-233	Ceiling	Classroom #233	10"x12"x1"	2																												
FCU-234	Ceiling	Classroom #234	10"x60"x1"	1																												
FCU-235	Ceiling	Classroom #235	10"x12"x1"	2																												
FCU-236	Ceiling	Classroom #236	10"x60"x1"	1																												
FCU-240A	Ceiling	Classroom #240	10"x12"x1"	2																												
FCU-241	Ceiling	Classroom #241	10"x12"x1"	2																												
FCU-243	Ceiling	Classroom #243	12"x15"x1"	2																												
FCU-246	Ceiling	Classroom #246	12"x15"x1"	2																												
FCU-246A	Ceiling	Classroom #246A	10"x12"x1"	2																												
FCU-248	Ceiling	Classroom #248	10"x60"x1"	1																												
FCU-250	Ceiling	Classroom #250	10"x60"x1"	1																												
FCU-252	Ceiling	Classroom #252	10"x60"x1"	1																												
FCU-254	Ceiling	Classroom #254	10"x60"x1"	1																												
FCU-256	Ceiling	Classroom #256	10"x60"x1"	1																												
FCU-256A	Ceiling outside room 256	Classroom #256	10"x12"x1"	2																												
FCU-258	Ceiling	Classroom #258	10"x48"x1"	1																												
FCU-306	Ceiling outside Classroom 306	Classroom #306	10"x12"x1"	2																												
FCU-307	Ceiling	Classroom #307	10"x36"x1"	1																												
FCU-309	Ceiling	Classroom #309	10"x36"x1"	1																												
FCU-311	Ceiling	Classroom #311	10"x48"x1"	1																												
FCU-313	Ceiling	Classroom #313	10"x60"x1"	1																												
FCU-313A	Ceiling	Classroom #313	10"x36"x1"	1																												
FCU-322	Ceiling	Classroom #322	10"x12"x1"	2																												
FCU-323	Ceiling	Classroom #323	10"x48"x1"	1																												
FCU-325	Ceiling	Classroom #325	10"x60"x1"	1																												
FCU-333	Ceiling	Classroom #333	10"x48"x1"	1																												
FCU-335	Ceiling	Classroom #335	10"x60"x1"	1																												
FCU-335A	Ceiling	Classroom #335A	10"x36"x1"	1																												
FCU-335B	Ceiling	Classroom #335	10"x12"x1"	2																												
FCU-340	Ceiling	Classroom #340	10"x60"x1"	1																												
FCU-340A	Ceiling	Classroom #340A	10"x12"x1"	2																												
FCU-341	Ceiling	Classroom #341	10"x48"x1"	1																												
FCU-342	Ceiling	Classroom #342	10"x60"x1"	1																												
FCU-346A	Ceiling	Classroom #346	10"x12"x1"	2																												
FCU-346B	Ceiling outside Classroom #346	Room #346	10"x12"x1"	2																												
FCU-348	Ceiling	Classroom #348	10"x60"x1"	1																												
FCU-350	Ceiling	Classroom #350	10"x72"x1"	1																												
FCU-352	Ceiling	Classroom #352	10"x72"x1"	1																												
FCU-353	Ceiling	Classroom #353	10"x12"x1"	2																												
FCU-354	Ceiling	Classroom #354	10"x72"x1"	1																												
FCU-355	Ceiling	Classroom #355	10"x12"x1"	2																												
FCU-356	Ceiling	Classroom #356	10"x72"x1"	1																												

Long Reach HS
Air Filter and Belt Inventory



Unit No.	Unit Location	Area Served	1" Filters				2" Filters				4" Filters				12" Filters				Belts																		
			Size 1	Quan.	Size 2	Prefilter?	Size 1	Quan.	Size 2	Quan.	Size 3	Quan.	Prefilter?	Size 1	Quan.	Header?	Size 2	Quan.	Header?	Size 1	Quan.	Header?	Size 2	Quan.	Header?	Size 1	Quan.	Size 2	Quan.	Size 3	Quan.	Size 4	Quan.				
FCU-358	Ceiling	Classroom #358	10"x60"x1"	1																																	
FCU-8F	Ceiling outside main office door	Main office	10"x12"x1"	2																																	
FCU-A102	Ceiling	Room #A102	10"x12"x1"	2																																	
FCU-A112	Ceiling outside A112	Room #A112	10"x12"x1"	2																																	
FCU-A121	Ceiling	Room #A121	10"x12"x1"	2																																	
FCU-A129	Ceiling outside room A129	Room #A129	12"x15"x1"	2																																	
FCU-A130	Ceiling outside room A130	Room A130	10"x12"x1"	2																																	
FCU-A136	Ceiling	Room A136	12"x15"x1"	6																																	
FCU-A137	Ceiling outside room A137	Room A137	10"x12"x1"	2																																	
FCU-A139	Ceiling	Room #139	12"x15"x1"	2																																	
FCU-B105	Ceiling	Room #B105	10"x12"x1"	2																																	
FCU-B109	Ceiling	Room #B109	12"x15"x1"	2																																	
FCU-B112	Ceiling	Room #B112	10"x60"x1"	1																																	
FCU-B114	Ceiling	Room #B114A	10"x48"x1"	1																																	
FCU-B114A	Paint Booth	Paint Booth	20"x20"x1"	1																																	
FCU-B115	Ceiling	Room #B115	12"x15"x1"	2																																	
FCU-B115A	Ceiling	Room #B115	10"x12"x1"	2																																	
FCU-B116	Ceiling	Room #B116	10"x60"x1"	1																																	
FCU-B122	Ceiling	Room #B122	10"x12"x1"	2																																	
FCU-B123	Ceiling	Room B123	12"x15"x1"	2																																	
FCU-B127	Ceiling	Staff Dining Lounge	10"x12"x1"	2																																	
FCU-B130A	Ceiling	Room #B130A	10"x36"x1"	1																																	
FCU-CAFE	Ceiling	Cafeteria	12"x15"x1"	8																																	
FCU-CS	Costume Storage	Costume Storage	15"x17"x1"	2																																	
FCU-KIT	Kitchen Ceiling	Kitchen	10"x28"x1"	1																																	
FCU-M	Ceiling	Media Center	12"x15"x1"	6																																	
FCU-M2	Ceiling	Media Center	10"x12"x1"	2																																	
FCU-SA	Ceiling Stairwell A	Stairwell A	10"x28"x1"	1																																	
FCU-SB	Ceiling Stairwell B	Stairwell B	10"x28"x1"	1																																	
FCU-SC	Ceiling Stairwell C	Stairwell C	10"x36"x1"	1																																	
FCU-SD	Ceiling	Stairwell D	10"x36"x1"	1																																	
HV-1	Next to Gym on 2nd Floor Mech room	Boy & Girl Locker Rooms																																	A61	2	
HV-2	Next to Gym on 2nd Floor Mech room	Auxiliary Gym																																	A48	1	
HV-3	Next to Gym on 2nd Floor Mech room	Main Gym																																	B86	2	
RAC-4	Roof	Locker Room office	20"x25"x1"	1																															No Belt		
RAHU-02	Roof	Cafe																																	B62	2	
RAHU-03	Roof	2nd and 3rd floor rooms																																	B92	1	
RAHU-04	Roof	Tech ED																																	B62	2	
RAHU-05	Roof	Media Center																																	B62	2	
RAHU-06	Roof	Atrium																																	B92	1	
RAHU-07	Roof	Band Room																																	A64	2	
RAHU-08	Roof	Admin Guidance																																	A67	1	
RAHU-09	Roof	Auditorium																																	B64	2	
RAHU-10	Roof	Stage																																	B67	3	
RAHU-11	Roof	Dance room																																	A79	2	
UV-202	Floor	Classroom #202	10"x48"x1"	1																															B62	2	
UV-204	Floor	Classroom #204	10"x36"x1"	1																															A59	1	
UV-206	Floor	Classroom #206	10"x60"x1"	1																																A64	2
UV-210	Floor	Classroom #210	10"x60"x1"	1																																A67	1
UV-212	Floor	Classroom #212	10"x60"x1"	1																																	
UV-214	Floor	Classroom #214	10"x60"x1"	1																																	
UV-216	Floor	Classroom #216	10"x60"x1"	1																																	
UV-218	Floor	Classroom #218	10"x60"x1"	1																																	
UV-240	Floor	Classroom #240	10"x60"x1"	1																																	
UV-242	Floor	Classroom #242	10"x60"x1"	1																																	
UV-244	Floor	Classroom #244	10"x60"x1"	1																																	
UV-248A	Floor	Classroom #248	10"x36"x1"	1																																	
UV-300	Floor	Classroom #300	10"x60"x1"	1																																	
UV-302	Floor	Classroom #302	10"x60"x1"	1																																	
UV-304	Floor	Classroom #304	10"x60"x1"	1																																	
UV-306	Floor	Classroom #306	10"x60"x1"	1																																	
UV-310	Floor	Classroom #310	10"x60"x1"	1																																	
UV-312	Floor	Classroom #312	10"x60"x1"	1																																	
UV-314	Floor	Classroom #314	10"x60"x1"	1																																	
UV-316	Floor	Classroom #316	10"x60"x1"	1																																	
UV-318	Floor	Classroom #318	10"x60"x1"	1																																	
UV-320	Floor	Classroom #320	10"x36"x1"	1																																	

Long Reach HS
Air Filter and Belt Inventory



Unit No.	Unit Location	Area Served	1" Filters			2" Filters						4" Filters						12" Filters						Belts														
			Size 1	Quan.	Size 2	Quan.	Prefilter?	Size 1	Quan.	Size 2	Quan.	Size 3	Quan.	Prefilter?	Size 1	Quan.	Header?	Size 2	Quan.	Header?	Size 1	Quan.	Header?	Size 2	Quan.	Header?	Size 1	Quan.	Size 2	Quan.	Size 3	Quan.	Size 4	Quan.				
UV-322	Floor	Classroom #322	10"x60"x1"	1																																		
UV-324	Floor	Classroom #324	10"x60"x1"	1																																		
UV-326	Floor	Classroom #326	10"x60"x1"	1																																		
UV-328	Floor	Classroom #328	10"x60"x1"	1																																		
UV-330	Floor	Classroom 330	10"x60"x1"	1																																		
UV-332	Floor	Classroom #332	10"x60"x1"	1																																		
UV-334	Floor	Classroom #334	10"x60"x1"	1																																		
UV-336	Floor	Classroom #336	10"x60"x1"	1																																		
UV-340	Floor	Classroom #340	10"x72"x1"	1																																		
UV-342	Floor	Classroom #342	10"x72"x1"	1																																		
UV-343	Floor	Classroom #343	10"x72"x1"	1																																		
UV-344	Floor	Classroom #344	10"x60"x1"	1																																		
UV-346	Floor	Classroom #346	10"x72"x1"	1																																		
UV-348A	Floor	Classroom #348	10"x36"x1"	1																																		
UV-P	Penthouse	Penthouse	10"x22"x1"	1																																		
Totals				192		1		142		34																									26	13		

SUMMARY	
Total # of Units	151
# of 1" Air Filters	193
# of 2" Air Filters	176
# of 4" Air Filters	0
# of 12" Air Filters	0
Total # of Air Filters	369
Total # of Belts	39